## GOVT, OF ASSAM OFFICE OF THE DIRECTOR. FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI



16171 - 18(2) Na Fats FPW ((VII)

Dated Cowahati the 3

The Principal. For Teachers Training College, Mirza, Dist:- Kamrup, Assam.

RENEWAL OF NO OBJECTION CERTIFICATE IN RESPECT OF INBUIL I FIRE FIGHTING FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE TEACHERS TRAINING COLLEGE LOCATED AT MIRZA, DIST:- KAMRUP, ASSAM.

With reference to your completion report under No. NII. and on the basis of the Inspection Report submitted by Station Officer, Into Boro, I hereby certify that the 10.05.2022 building as per description below at Dag No 1881(O), 2007(N) Patta No - Mouza Chayani, (Place-Mirza) has been inspected in respect of implementation of inbuilt. Fire Lighting, Fire Prevention Escape means measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No Objection in its occupation futilization for the purpose of COLLEGE subject to conditions mentioned below

DETAILS OF APPROVED OCCUPATION

GROUND FLOOR

1. Floor area - Block 'A'= 491.4 m', Block 'B'= 588 m'

2 Purpose of utilization -

For Classroom & Others Activity Rooms Purpose.

Details of Fire Fighting measures found in working condition:

- 1 Hose Reel Hose system
- 2 Down Comer system
- 3 Manually Operated Electric Fire Alarm system
- 4 Fire Extinguishers-15 Nos
- 5 Terrace Water Tank
- 6 Terrace Pump

S.P. cum F&ESSANJA

for and on hebricat Ssam, Guwahan

Dated Guwahati the

NO FAES/FPW!

Copy to.

1 The Deputy Commissioner, Kamrup, Amingaon, Assam for information

The Superintendent of Police, Kamrup, Amingaon, Assam for information

3 The President/ Secretary, 105 No. Kochpara Gaon Panchayat, Assam for information

4 The Station Officer, Mirza F&ES Station, for information and necessary action

S.P. cum F&ES Adviser, for and on behalf of Director of Fire and Emergency Services, Assam, Guwahati

## CONDITIONS:

- 1 The N.O.C. is valid up to 31.03.2023
- 2 There should not be any change of Trade for which this License has been issued.
- 3. There should not be any structural change in the building either horizontally or vertically There should not also be any change in the existing arrangements
- 4 The Fire Fighting equipments should be in serviceable condition at all time
- 5 Water reservoir should always be kept full up to brim
- 6. The entrance and exit and the water reservoir should always be free from any obstruction. projection
- 7. The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.

for and on behind there.
Director of Fire and I mercants Samuella Samuella